



# **TEST / CALIBRATION REPORT**

## **Type Test Report for MECO AC Voltage Transducer Testing as per IEC 60688 (Edition 2.2)**



**ELECTRONICS REGIONAL TEST LABORATORY (WEST)**  
**MINISTRY OF COMMUNICATIONS & INFORMATION TECHNOLOGY, (STQC Dte.)**

**Government of India**

Plot No. F 7 & 8, MIDC Area, Opp. SEEPZ,  
Andheri (E), Mumbai-400 093.  
Phone : (022) 2832 5134, 2830 1468, 2830 1138 Fax : (022) 2822 5713  
E-mail : ertlbom@bom4.vsnl.net.in

## **MEMORANDUM**

The Test/Calibration Report issued by **ERTL (W)** is a record of the measurements conducted on the products submitted to it for testing / calibration and the results thereof. Unless otherwise specified in the report, the results are applicable only to those products which have been tested / calibrated and do not apply to other products even though declared to be identical.

This Report, if reproduced for any purpose-commercial or otherwise would be reproduced in full. Reproduction of a part of the report or an abstract thereof must be specifically approved from the **ERTL (W)**.

## **LIABILITY CLAUSE**

1. **ERTL (W)** shall not be liable for any change in test / calibration data and performance specification on account of malfunctioning of the standard / instrument /equipment due to any damage caused to it after the report, in respect of it has been issued
2. The report shall not be regarded in any way diminishing the normal contractual responsibilities / obligations between the customer and **ERTL (W)**.
3. The result reported in this report are valid only at the time of and under the stated conditions of the measurements.

ELECTRONICS REGIONAL TEST LABORATORY (WEST) DEPARTMENT OF INFORMATION TECHNOLOGY	REPORT NO. ERTL (W)/2003 E&S26		
SUBJECT: TESTING OF AC VOLTAGE TRANSDUCER	DATE <b>9 MAY 2003</b>	PAGE 1	OF 7

1. SCOPE

1.1 Service Request No : ERTL(W)/20030563 DATED 21<sup>st</sup> March 2003

1.1.1 Service Request finalised on : 21<sup>st</sup> March 2003

1.2 Requested by : MECO INSTRUMENTS PVT LTD.,  
(Name and address of organisation) 301, BHARAT INDUSTRIAL EASTATE,  
T.J. ROAD, SEWREE (W),  
MUMBAI - 400 015.

1.3	<u>Description</u>	<u>Qty</u>	<u>Manufacturer</u>	<u>Type No.</u>	<u>Serial Nos.</u>
	AC VOLTAGE TRANSDUCER, INPUT : 0 - 132 VAC, OUTPUT : 0 - 10 mA & 4 - 20 mA Accuracy: 0.2 %	01 No.	MECO	VMT	030932


1.4 Test specifications : Testing as per IEC 60688 (Edition 2.2)

1.5 Lab Ambient : Temperature: (25 ± 2) ° C  
RH : (55 ± 5) %

1.6 Test Equipment used :

1) Calibration System	S&C/138
2) Energy Meter Calibrator	E&S/126
3) System DMM	EMI/006
4) Vibration Machine	ENV/008
5) Shock Test Machine	ENV/018
6) Over Voltage Test Generator	EMI/002
7) HF Test Generator	EMI/019
8) Coupling Network	EMI/021
8) Programmable Humidity Chamber	ENV/042

Release



SUBJECT: TESTING OF AC VOLTAGE TRANSDUCER

DATE

9 MAY 2003

PAGE


2

OF

7

**2.0 Test Results**

Sr.No	Reference Clause No.	Test/Parameter	Test Condition	Requirement	Observation		Remark
					O/p 1	O/p 2	
2.1	4.2	Intrinsic error	Auxiliary power supply : 48 V DC. a) Input voltage = 0 V AC b) Input voltage = 66 V AC c) Input voltage = 132 V AC	Class index (0.2 %)	-0.05 % -0.06 % -0.05 %	0.02 % -0.05 % -0.05 %	Complied
2.2	6.2	Variation due to auxiliary supply voltage	Aux. Voltage varied from 38.4 V to 57.6 V	50 % of class index	0.01 %	0.03 %	Complied
2.3	6.4	Variation due to ambient temp.	Auxiliary power supply : 48 V DC Temp. varied from 0 deg. C to 45 deg. C	100 % of class index	1.56 %	2.49 %	Called customer, Dry solder at one joint found which was rectified and test repeated. The result of retest reported at Sr. No. 2.3.1
2.3.1	6.4	Retesting of Variation due to ambient temp.	Auxiliary power supply : 48 V DC Temp. varied from 0 deg. C to 45 deg. C	100 % of class index	0.09 %	0.2 %	
2.3	6.5	Variation due to frequency of input quantities	Auxiliary power supply : 48 V DC Input frequency varied from 45 Hz to 55 Hz.	50 % of class index	0.17 %	0.2 %	Complied
2.4	6.9	Variation due to output load	Auxiliary power supply : 48 V DC <b>Output 1:</b> Output load resistance varied from 0 ohm to 1000 ohm. <b>Output 2:</b> Output load resistance varied from 0 ohm to 500 ohm.	50 % of class index	0.01 %	0.01 %	Complied



ELECTRONICS REGIONAL TEST LABORATORY (WEST) DEPARTMENT OF INFORMATION TECHNOLOGY		REPORT NO. ERTL (W)/2003 E&S 26	
SUBJECT: TESTING OF AC VOLTAGE TRANSDUCER		DATE <b>19 MAY 2003</b>	PAGE 3 OF 7

Sr.No	Reference Clause No.	Test/Parameter	Test Condition	Requirement	Observation		Remark
					O/p 1	O/p 2	
2.5	6.10	Variation due to distortion of input quantities	Auxiliary power supply : 48 V DC I/p with 20 % 3 <sup>rd</sup> harmonics	200 % of Class index	0.17 %	0.17 %	Complied
2.6	6.11	Variation due to magnetic field of external origin	Auxiliary power supply : 48 V DC Magnetic field of 0.4 kA/m	Class index	0.02 %	0.03 %	Complied
2.7	6.14	Variation due to self heating	Auxiliary power supply : 48 V DC Test duration: 35 min.	Class index	0.18 %	0.14 %	Complied
2.8	6.15	Variation due to continuous operation	Auxiliary power supply : 48 V DC Test duration: 6 h	Continue to comply the accuracy class	0.2 %	0.19 %	Complied
2.9	6.16	Variation due to common mode interference	Auxiliary power supply : 48 V DC With 100 Vrms at 45 Hz to 65 Hz applied between either output terminal and earth.	Class index	0.01 %	0.02 %	Complied



ELECTRONICS REGIONAL TEST LABORATORY (WEST) DEPARTMENT OF INFORMATION TECHNOLOGY		REPORT NO. ERTL (W)/2003 E&S 26	
SUBJECT: TESTING OF AC VOLTAGE TRANSDUCER		DATE <b>9 MAY 2003</b>	PAGE 4 OF 7

Sr.No.	Reference Clause No.	Test/Parameter	Test Condition	Requirement	Observation		Remark
					O/p 1	O/p 2	
2.10	6.17	Variation due to series mode interference	Auxiliary power supply : 48 V DC With 1 V rms at 45 Hz to 65 Hz applied in series with output signal	Class index	0.03 %	0.01 %	Complied
2.11	6.18	Permissive excessive inputs					
2.11.1	6.18.1	Continuous excessive inputs	Auxiliary power supply : 48 V DC Apply 120 % of nominal upper value on aux. Supply, voltage inputs and current inputs.	Continue to comply the accuracy class after test	Complied	Complied	Complied
2.11.2	6.18.2	Excessive inputs of short duration	a) For voltage inputs: 200 % of the nominal value of the measured voltage applied for 1 s and repeated 10 times at 10 s interval. b) For current inputs: 20 times the nominal value of the measured current applied for 1 s and repeated 5 times at 300 s interval	Continue to comply the accuracy class after test	Complied	Complied	Complied
2.12	6.20	Voltage test,	At 3 kV AC for 1 min. between a) Input & output b) Aux. & output c) Aux. & input	No breakdown	No breakdown observed.		Complied



ELECTRONICS REGIONAL TEST LABORATORY (WEST)  
DEPARTMENT OF INFORMATION TECHNOLOGY

REPORT NO. ERTL (W)/2003 E&S 26

SUBJECT: TESTING OF AC VOLTAGE TRANSDUCER

DATE

9 MAY 2003

PAGE

5

OF

7

Sr.No.	Reference Clause No.	Test/Parameter	Test Condition	Requirement	Observation		Remark
					Output 1	Output 2	
2.13	6.20	Impulse voltage tests	At peak test voltage of 5 kV in both positive and negative senses having the standardized impulse waveform of 1.2/50 us, applied between terminals of each circuit in turn and all other circuit connected together.	After completion of the test the DUT shall comply with the requirement appropriate to its class index.			Complied
2.13.1	4.2	Intrinsic error	Auxiliary power supply : 48 V DC a) Input voltage = 0 V AC b) Input voltage = 66 V AC c) Input voltage = 132 V AC	Class index (0.2 %)	-0.02 % -0.02 % 0.05 %	-0.01 % 0.06 % 0.02 %	Complied
2.14	6.21	High frequency disturbance test	2.5 kV peak between independent circuits. 1kV peak between terminals of the same circuit.	The variation due to the effect of disturbance shall not be twice of class index.	Complied	Complied	Complied
2.14.1	4.2	Intrinsic error	Auxiliary power supply : 48 V DC c) Input voltage = 0 V AC d) Input voltage = 66 V AC e) Input voltage = 132 V AC	Class index (0.2 %)	-0.03 % 0.01 % 0.03 %	-0.01 % 0.01 % 0.02 %	Complied
2.15	6.22	Test for temp. rise	Current circuit loaded at 110 % for 2 h Voltage circuit loaded at 120 % for 2 h	For input circuits: 60 k For exterior surface: 25 k	Not discernible	Not discernible	Complied




ELECTRONICS REGIONAL TEST LABORATORY (WEST) DEPARTMENT OF INFORMATION TECHNOLOGY		REPORT NO. ERTL (W)/2003 E&S 26	
SUBJECT: TESTING OF AC VOLTAGE TRANSDUCER		DATE	PAGE
		26 SEP 2003	6
			OF
			7

Sr.No.	Reference Clause No.	Test/Parameter	Test Condition	Requirement	Observation		Remark
					Output 1	Output 2	
2.16	6.23	Vibration	Freq. : 10 - 55 - 10 Hz. Amplitude: 0.15 mm. 5 cycles, 1 octave/min. Axis: Vertical		Conditioned		---
2.16.1	4.2	Intrinsic error	a) Input voltage = 0 V AC b) Input voltage = 66 V AC c) Input voltage = 132 V AC	Class index (0.2%)	-0.03 % -0.08 % 0.02 %	-0.01 % -0.04 % 0.02 %	Complied
2.17	6.23	Shock	15g, 1/2 sine, 11 ms, 3 shocks on each sense. Total 18 shocks.		Conditioned		---
2.17.1	4.2	Intrinsic error	a) Input voltage = 0 V AC b) Input voltage = 66 V AC c) Input voltage = 132 V AC	Class index (0.2%)	-0.04 % -0.03 % 0.13 %	-0.02 % -0.01 % 0.07 %	Complied
2.18	6.23	Drop & topple	Drop height: 25 mm, one drop about each of four bottom edges. One topple about each of four bottom edges.		Conditioned		---
2.18.1	4.2	Intrinsic error	a) Input voltage = 0 V AC b) Input voltage = 66 V AC c) Input voltage = 132 V AC	Class index (0.2%)	-0.02 % -0.04 % 0.09 %	-0.01 % -0.04 % 0.06 %	Complied
2.19	5.2.3	Open circuit voltage	Auxiliary power supply : 48 V DC Input voltage = 132 V AC		13.47 V	14.43 V	---
2.20	5.4	Ripple	Auxiliary power supply : 48 V DC Input voltage = 132 V AC	Not exceed twice of class index	0.34 %	0.35 %	Complied
2.21	5.5	Response time	Auxiliary power supply : 48 V DC Input voltage switched from 0 to 132 V AC	Time required for output signal to reach 99 % from 0 % of fiducial value shall be reported	137 ms	135 ms	---

Addendum Approved by

*(Signature)*  
(Head, E&S)



This is an addendum version of Page No. 06 of 07 of Report No. ERTL (W)/2003E&S26 issued on 9th May 2003.



ELECTRONICS REGIONAL TEST LABORATORY (WEST) MINISTRY OF INFORMATION TECHNOLOGY	REPORT NO. ERTL (W)/2003 E&S 26		
SUBJECT: TESTING OF AC VOLTAGE TRANSDUCER	DATE <b>9 MAY 2003</b>	PAGE 7	OF 7

3.0 General Remarks : Nil.

REPORT APPROVED BY

REPORT RELEASED BY

*[Handwritten Signature]*  
HEAD (E&S)



OIC (CSC)

## OUR ACCREDITATION STATUS

ERTL (W) set up under the STQC Directorate, Ministry of Communications & Information Technology, Govt. of India has been accredited under number of national / international systems as follows :

SYSTEM	AREA	STATUS
<b>IECQ</b> (International Electro-technical Commission on Quality Assessment System for Electronic Components)	<b>Component Testing</b> <ul style="list-style-type: none"> <li>● Resistors (Fixed)</li> <li>● Capacitors (Fixed)</li> </ul>	Accredited as ITL (Independent Test Laboratory)
<b>NABL (C), India</b> National Accredital Board for Test & Calibration laboratories (Calibration System)	<b>Calibration</b> <ul style="list-style-type: none"> <li>● Electro-technical discipline</li> <li>● Thermal discipline</li> <li>● Mechanical discipline</li> </ul>	Accredited Calibration Laboratory
<b>NABL(T), India</b> National Accredital Board for Test & Calibration laboratories (Testing System)	Electronic & Electrical Testing	Accredited Test Laboratory
<b>IECEE-CE-Scheme</b>	<ul style="list-style-type: none"> <li>● Mains Operated Electronic Consumer Products</li> </ul>	Approved as a CB test Laboratory
<b>Other recognition</b>		Recognised by CSPO of State Govt., DOT, Naval Docyard, LCSO etc.